

Joint lubrication may be used as an aid when assembling Z-DENS components together.

If required, the joint lubricant may be applied in one of two ways (reference single wall rigid pipe shown below for illustration purposes);

1. Apply a thin film of lubricant, sparingly, to the leading edge of the gasket that is seated in the female end of pipe/fitting.

or

2. Apply a thin film of lubricant to the outside leading edge of male end of pipe/fitting.

Insert the pipe evenly using a slow twisting motion until properly seated.
Refer to the Z-DENS Installation Manual on our website.

Vent	Approximate # of joints per 30g tube*
2	44
3	40
4	34
5	26
6	20
8	18

**Note: The number of joints per 30g tube is approximation only.*

